

Table 3B  
**minimum wet pendulum test or oil-wet inclining platform  
classifications for applications where the NCC does not  
require slip resistance**

Location	Wet pendulum test	Oil-wet inclining platform test
<b>External Pavements and Ramps</b>		
External ramps including driveways, footpaths etc steeper than 1:14	P5	R12
External ramps including driveways, footpaths etc under 1:14, external sales areas (eg. markets), external carpark areas, external collonades, walkways, pedestrian crossings, balconies, verandas, carports, driveways, courtyards and roof decks	P4	R11
Undercover car parks	P3	R10
<b>Hotels, Offices, Public Buildings, Schools and Kindergartens</b>		
Entries and access areas including hotel, offices, public buildings, schools, kindergartens, common areas of public buildings, internal lift lobbies		
Wet Areas	P3	R10
Transitional Area	P2	R9
Dry Area	P1 (see note 3)	R9
Toilet facilities in offices, hotels and shopping centres	P3	R10
Hotel apartment bathrooms, en suites and toilets	P2	A
Hotel apartment kitchens and laundries	P2	R9
<b>Supermarkets and Shopping Centres</b>		
Fast food outlets, buffet foos servery areas, food courts and fast food dining areas in shopping centres	P3	R10
Shop and supermarket fresh fruit and vegetable areas	P3	R10
Shop entry areas with external entrances	P3	R10
Supermarket aisles (except fresh fruit areas)	P1 (see note 3)	R9
Other separate shops inside shopping centres - wet	P3	R10
Other separate shops inside shopping centres - dry	P1 (see note 3)	R9
<b>Loading Docks, Commercial Kitchens, Cold Stores, Serving Areas</b>		
Loading docks under cover and commercial kitchens	P5	C
Serving areas behind bars in public hotels and clubs, cold stores and freezers	P4	R11
<b>Swimming Pools and Sporting Facilities</b>		
Swimming pool ramps and stairs leading to water	P5	C
Swimming pool surrounds and communal shower rooms	P4	B
Communal changing rooms	P3	A
Undercover concourse areas of sports stadiums	P3	R10
<b>Hospitals and Aged Care Facilities</b>		
Bathrooms and en suites in hospitals and aged care facilities	P3	B
Wards and corridors in hospital and aged care facilities	P2	R9

**Note 3**

The minimum classifications listed in Table 3B are P1 and R9. It is inappropriate for Table 3B to list the lower classification, P0, since there is no lower limit on Classification P0.

Notwithstanding, some smooth and polished floor surfaces, which do not achieve Classification P1, may be considered to provide a safe walking environment for normal pedestrians walking at a moderate pace, provided the surfaces are kept clean and dry; however, should these surfaces become contaminated by either wet or dry materials, or be used by pedestrians in any other manner, then they may become unsafe.

Therefore, the type of maintenance, the in-service inspection of floors, other environmental conditions and use should be taken in to account when selecting such products.